




Federation Council Standard Drawing Index

Series 800 - Water


SD 800 - Water Service House Connection - Main on same side of road as Lot

SD 801 - Water Service House Connection - Main on opposite side of road as Lot

SD 802 - Water Service House Connection - Meter Connection Details



**Section A-A**  
Not to Scale



**Plan**  
Not to Scale

**NOTES:**

1. All sealed roads to be underbored.
2. All measurements are in millimetres unless otherwise stated.
3. Gravel roads to be backfilled with DGB20 gravel.
4. New services located 0.5m from left side of property boundary U.N.O.
5. Valve & tap assembly to be NSW type approved.
6. Live Water Tappings to be coordinated with Councils Water & Sewer Coordinator.



Standard Drawing



LAST UPDATED: 11/12/18

FILE PATH: A4  
N:\\_Design Manual\Federation Council Standard Drawings & Development Guidelines\Standard Drawings\800 SERIES - WATER\800 SERIES.dwg

**WATER SERVICE HOUSE CONNECTION**  
MAIN ON SAME SIDE OF ROAD AS LOT

SD800

REV  
A



**NOTES:**

1. All sealed roads to be underbored.
2. All measurements are in millimetres unless otherwise stated.
3. Gravel roads to be backfilled with DGB20 gravel.
4. New services located 0.5m from left side of property boundary.
5. Valve & tap assembly to be NSW type approved.
6. Live Water Tappings to be coordinated with Councils Water & Sewer Coordinator.



Standard Drawing


LAST UPDATED: 11/12/18

FILE PATH: A4  
 N:\\_Design Manual\Federation Council Standard Drawings & Development Guidelines\Standard Drawings\800 SERIES - WATER\800 SERIES.dwg

**WATER SERVICE HOUSE CONNECTION**  
 MAIN ON OPPOSITE SIDE OF ROAD FROM LOT

**SD801**

REV  
A



**NOTES:**

- 1. Stop tap with packing gland to be used – ball valves are not permitted.
- 2. 25mm is standard size for water meter – any larger will be designed upon request.



Standard Drawing

LAST UPDATED: 11/12/18	
FILE PATH:	A4
N:\_Design Manual\Federation Council Standard Drawings & Development Guidelines\Standard Drawings\800 SERIES - WATER\800 SERIES.dwg	
SD802	REV A

**WATER SERVICE HOUSE CONNECTION**  
METER CONNECTION DETAILS